



Youngstown Tube

"Quality by the Foot"



Schedule 7 Sprinkler Pipe "Fire-Flo"

Youngstown Tube manufactures Fire-Flo (schedule 7) pipe in sizes 1 1/2" thru 4" using only high quality **domestic** steel coils. This ensures a uniform superior product for roll grooving, welding or plain end uses. Youngstown Tube's Fire-Flo pipe is produced under ASTM A135/A795 Type E, Grade A, NH standards. Every piece is Eddy-Current tested and conforms to internal SPC testing and recording.

Fire-Flo pipe is manufactured with lighter gauge steel than conventional schedule 10 pipe. This creates a lighter, cost effective product with increased hydraulics over schedule 10 pipe.

Youngstown Tube Fire-Flo steel sprinkler pipe is coated with a waterbased black enamel coating, YTC Guard® antimicrobial coating and a continuous color coded **yellow** stencil, and **stored indoors** ready for immediate shipment.

Approvals: UL Listed, CUL Listed, FM Approved

Youngstown Tube schedule 7 pipe meets the rigorous testing and certification processes of Underwriters Laboratory and Factory Mutual for steel sprinkler pipe with working pressures of 300 psi or less. It also meets the requirements of NFPA 13.

"Fire-Flo" Schedule 7 *

Pipe Size	Pipe OD	Pipe ID	Nominal Wall	Weight per Foot	Standard Length	Pieces per Bundle	Feet per Bundle	Weight per Bundle	UL Unthreaded CRR
1 1/2	1.900	1.732	.084	1.62	21	61	1,281	2,075	2.85
2	2.375	2.207	.084	2.05	21	37	777	1,593	2.31
2 1/2	2.875	2.703	.086	2.55	21	30	630	1,607	1.43
3	3.500	3.314	.093	3.38	21	19	399	1,349	1.34
4	4.500	4.304	.098	4.37	21	19	399	1,744	1.0

* Fire-Flo pipe can not be threaded or cut-grooved.

Youngstown Tube Company
401 Andrews Avenue
Youngstown, Ohio 44505
1-866-The-Tube
www.youngstowntube.com

Project:

Contractor:

Submitted By:

Date Submitted: